

Drexel Heights Fire District

2012 International Fire Code Amendments

February 15, 2013 Drexel Heights Fire District adopted the International Fire Code 2012 edition in its entirety unless otherwise amended below.

CHAPTER 1 SCOPE AND ADMINISTRATION

SECTION 101 - SCOPE AND GENERAL REQUIREMENTS

Section 101.1 Title. Is amended to read:

Title. These regulations shall be known as the *Fire Code* of Drexel Heights Fire District, hereinafter referred to as “this code.”

Section 101.2.1 Appendices. Is amended to read:

Appendices. The following appendices are adopted as part of this code:

APPENDIX B, FIRE-FLOW REQUIREMENTS FOR BUILDINGS

APPENDIX C, FIRE HYDRANT LOCATIONS AND DISTRIBUTION

APPENDIX D, FIRE APPARATUS ACCESS ROADS

APPENDIX H, HAZARDOUS MATERIALS MANAGEMENT PLAN

(HMMP) AND HAZARDOUS MATERIALS INVENTORY STATEMENT (HMIS)
INSTRUCTIONS

APPENDIX I, FIRE PROTECTION SYSTEMS-NONCOMPLIANT
CONDITIONS

SECTION 113 - FEES

Section 113.2 Schedule of permit fees. Is amended to read:

Schedule of permit fees. Permit fees shall be in accordance with the Drexel Heights Fire District fee schedule.

CHAPTER 2 DEFINITIONS

SECTION 202 - GENERAL DEFINITIONS

Driveway. Is added to read:

Driveway. A vehicular ingress and egress route that serves no more than two buildings or structures, not including accessory structures, or no more than five dwelling units.

Drexel Heights Fire District

2012 International Fire Code Amendments

Institutional Group I-1. The first sentence is amended to read:

Institutional Group I-1. This occupancy shall include buildings, structures or parts thereof for more than 10 persons who reside on a 24-hour basis in a supervised environment and receive custodial care.

Institutional Group I-1, Six to sixteen persons receiving care. Is amended to read:

Six to ten persons receiving care. A facility such as above, housing at least six and not more than 10 persons receiving such care, shall be classified as Group R-4.

Residential Group R-3. Is amended to read:

Residential Group R-3. Residential occupancies where the occupants are primarily permanent in nature and not classified as Group R-1, R-2, R-4 or I, including:

- Boarding houses (transient or non-transient) with 10 or fewer occupants
- Buildings that do not contain more than two *dwelling units*
- Care facilities that provide accommodations for five or fewer persons receiving care
- Congregate living facilities (transient or non-transient) with 10 or fewer occupants

Residential Group R-4. The first sentence is amended to read:

Residential Group R-4. This occupancy shall include buildings, structures or portions thereof for more than five but not more than 10 persons, excluding staff, who reside on a 24-hour basis in a supervised residential environment and receive custodial care.

CHAPTER 3 GENERAL REQUIREMENTS

SECTION 311 - VACANT PREMISES

Section 311.5 Placards. Is amended to read:

Placards. When determined by the *fire code official* any vacant or abandoned buildings or structures determined to be unsafe pursuant to Section 110 of this code relating to structural or interior hazards shall be marked as required by Sections 311.5.1 through 311.5.5.

CHAPTER 5 FIRE SERVICE FEATURES

SECTION 505 - PREMISES IDENTIFICATION

Section 505.1 Address numbers. Is amended to read:

Address numbers. New and existing buildings shall have *approved* address numbers, building numbers or *approved* building identification placed in a position that is plainly

Drexel Heights Fire District

2012 International Fire Code Amendments

legible and visible from the street or road fronting the property. Address numbers shall be in accordance with Pima County address display requirements. Address numbers shall be maintained at all times.

SECTION 507 - FIRE PROTECTION WATER SUPPLIES

Section 507.5.7 Reflective Pavement Markers. Is added to read:

Reflective Pavement Markers. To identify the fire hydrant location, a blue reflective marker shall be installed in the center of the public right away or the appropriate fire access drive lane perpendicular to the nearest fire hydrant.

CHAPTER 9 FIRE PROTECTION SYSTEMS

SECTION 901 - GENERAL

Section 901.2 Construction Documents. Is amended by adding a second paragraph:

Automatic fire protection system hydraulic calculations shall be based upon 90 percent of the available water supply as determined by the local water purveyor or flow test information.

Section 901.4 Installation. Is amended to read:

Installation. *Fire protection systems* shall be maintained in accordance with the original installation standards for that system. Systems shall be extended, altered, or augmented as necessary to maintain and continue protection whenever the building is altered, remodeled or added to. *Alterations to fire protection systems* shall be done in accordance with applicable standards.

Section 901.4.2 Nonrequired fire protection systems. Is deleted in its entirety.

Section 901.4.6 Pump and riser room size. Is amended to read:

Pump and riser room size. Fire pump and *automatic sprinkler system* riser rooms shall be located in a dedicated room and have a door directly accessible from the exterior of the building. The room shall be designed with adequate space for all equipment necessary for the installation, as defined by the manufacturer, with sufficient working space around the stationary equipment. Clearances around equipment to elements of permanent construction, including other installed equipment and appliances, shall be sufficient to allow inspection, service, repair or replacement without removing such elements of permanent construction or disabling the function of a required fire-resistance-rated assembly. Fire pump and automatic sprinkler system riser rooms shall

Drexel Heights Fire District

2012 International Fire Code Amendments

be provided with a door(s) and an unobstructed passageway large enough to allow removal of the largest piece of equipment.

Section 903 - AUTOMATIC FIRE SPRINKLER SYSTEMS

Section 903.2.1 Group A. Is amended to read:

Group A. An *automatic sprinkler system* shall be provided throughout all Group A occupancies.

Section 903.2.1.1 through Section 903.2.1.5. Is deleted in its entirety.

Section 903.2.3 Group E. Is amended to read:

Group E. An *automatic sprinkler system* shall be provided throughout all Group E occupancies.

Section 903.2.4 Group F-1. Is amended to read:

Group F. An *automatic sprinkler system* shall be provided throughout all Group F occupancies.

Section 903.2.4.1. Is deleted in its entirety.

Section 903.2.6 Group I. Is amended to read:

Group I. An *automatic sprinkler system* shall be provided throughout all Group I occupancies.

Section 903.2.7 Group M. Is amended to read:

Group M. An *automatic sprinkler system* shall be provided throughout all Group M occupancies.

Section 903.2.8.1 Group R-3 or R-4 congregate residences. Is amended to read:

Group R-3 or R-4 congregate residencies. An *automatic sprinkler system* installed in accordance with section 903.3.1.3 shall be permitted in Group R-3 or R-4 congregate living facilities with 10 or fewer residents.

Section 903.2.9 Group S-1. Is amended to read:

Group S-1. An *automatic sprinkler system* shall be provided throughout all Group S-1 occupancies.

Section 903.2.9.1 through Section 903.2.9.2. Is deleted in its entirety.

Section 903.2.10 Group S-2. Is amended to read:

Drexel Heights Fire District

2012 International Fire Code Amendments

Group S-2. An *automatic sprinkler system* shall be provided throughout all Group S-2 occupancies.

Section 903.2.10.1. Is deleted in its entirety.

Section 903.4.2.1 Water-flow notification devices. Is added to read:

Water-flow notification devices. An *approved* audible/visual notification appliance shall be installed in a normally occupied interior area of each building or each individual tenant space at the time of a tenant improvement. ADA restrooms within the same area shall have a visual notification appliance located within the room. Such sprinkler water-flow notification devices shall be activated by the water flow of a single sprinkler installed in the system.

Section 912 - FIRE DEPARTMENT CONNECTIONS

Section 912.2 Location. Is amended to read:

Location. Fire department connections shall be located a maximum of 200 feet (60,960mm) from the nearest fire hydrant. With respect to hydrants, driveways, buildings and landscaping, fire department connections shall be so located that fire apparatus and hose connected to supply the system will not obstruct access to the buildings for other fire apparatus. The location of fire department connections shall be *approved* by the *fire code official*.

APPENDIX D FIRE APPARATUS ACCESS ROADS

SECTION D103 - MINIMUM SPECIFICATIONS

Section D103.1.1 Driveways. Is added to read:

Driveways. Driveways providing access to single family *dwelling units* shall provide a minimum unobstructed width of 14 feet (4,267mm) and a minimum unobstructed height of 13 feet 6 inches (4,115mm). Driveways in excess of 150 feet (45,720mm) in length shall provide turnarounds. Driveways in excess of 200 feet (6,096mm) in length and less than 20 feet (6,096mm) in width shall provide turnouts in addition to turnarounds. Driveway turnouts shall be an all-weather road surface at least 10 feet (3,048mm) wide and 30 feet (9,144mm) long. Driveway turnouts shall be located as required by the *fire code official*.

Driveway turnarounds shall have an inside turning radius of not less than 30 feet (9,144mm) and an outside turning radius of not less than 45 feet (13,716mm). Driveways that connect with a road or roads at more than one point may be considered

Drexel Heights Fire District 2012 International Fire Code Amendments

as having a turnaround if all changes of direction meet the radius requirements for driveway turnarounds.

A driveway shall not serve in excess of five dwelling units.

Section D103.5 Fire apparatus access road gates. Item 1. Is amended to read:

1. The minimum gate width shall be an unobstructed 20 feet (6,096mm) when serving two directions, or an unobstructed 14 feet (4,267mm) when serving a single direction.

Section D103.5 Fire apparatus access road gates. Item 5. Is amended to read:

5. All electric gates shall be equipped with and have installed, *approved* pre-emptive control opening equipment and key switch compatible with the fire department's existing system.

Electric gates serving five or less single family *dwelling units* may utilize an approved key switch only.

Section D103.5 Fire apparatus access road gates. Item 10. Is added to read:

10. A key box shall be installed outside the access road gate and shall contain keys to gain access on to the property. The key box shall be maintained in accordance with Section 506.2.